

## Environmental Protection Agency

## § 406.25

### Subpart B—Corn Dry Milling Subcategory

#### § 406.20 Applicability; description of the corn dry milling subcategory.

(a) The provisions of this subpart are applicable to discharges resulting from the process in which shelled corn is washed and subsequently milled by dry processes into such products as corn meal, grits, flour, oil, and animal feed.

(b) The provisions of this subpart do not apply to discharges from subsequent manufacturing operations to produce expanded or extruded feed or feed products.

#### § 406.21 Specialized definitions.

For the purpose of this subpart:

(a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.

(b) The term *corn* shall mean the shelled corn delivered to a plant before processing.

(c) The term *standard bushel* shall mean a bushel of shelled corn weighing 56 pounds.

(d) The abbreviation *MSBu* shall mean 1000 standard bushels.

#### § 406.22 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Metric units (kilograms per 1,000 kg of corn)		
BOD <sub>5</sub> .....	0.21	0.07
TSS .....	0.18	.06
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
English units (pounds per 1,000 stbu of corn)		
BOD <sub>5</sub> .....	12.0	4.0
TSS .....	10.5	3.5
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 10513, Mar. 20, 1974, as amended at 60 FR 33936, June 29, 1995]

#### § 406.23 [Reserved]

#### § 406.24 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH .....	No limitation.
BOD <sub>5</sub> .....	Do.
TSS .....	Do.

[40 FR 6436, Feb. 11, 1975, as amended at 60 FR 33936, June 29, 1995]

#### § 406.25 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this part:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Metric units (kilograms per 1,000 kg of corn)		
BOD <sub>5</sub> .....	0.11	0.036
TSS .....	0.054	0.18
pH .....	( <sup>1</sup> )	( <sup>1</sup> )